

INDUSTRIAL WASTEWATER DISCHARGE PERMIT

Permit no. Durant-05-05-04-03

Modification dated 4/28/2022

Facility name: **Cardinal FG**
Location Address: **515 Cardinal Parkway Durant, OK 74701**
Mailing Address: **515 Cardinal Parkway Durant, OK 74701**
Telephone: **(580) 924-2412**

The purpose of this modification is to comply with an ODEQ Pretreatment Compliance Inspection conducted at the City of Durant Pretreatment Coordinator's office on August 12, 2021 and their findings in a letter dated April 20, 2022, which specifically requires the City to set permit limits issued to industries in accordance with Ordinance 1590. Therefore, in following with the inspection findings, the City implements the following changes to the permit referenced above.

After reviewing the inspection report and deficiencies cited, due to a typographical error, the City now provides the following changes to the permit.

To comply with the pretreatment program requirements for metals discharge limits to be equal to the City's pretreatment Ordinance 1590,

1. Molybdenum discharge limit will be set at 0.37 mg/L
2. Total cyanide discharge limit will be set at 0.53 mg/L

This will go in effect immediately to be added to existing permit requirements due to expire June 30, 2025.

By: 

George McAusland, Pretreatment Coordinator

By: 

John Dean, City Manager

Issued this 28 day of April, 2021